



Jefferson County West Virginia

Public Information

TABLE 8
SUMMARY OF PRIVATE SANITARY SEWER I&I RELATED DEFECTS (IN WHICH AN I&I QUANTITY CAN NOT BE REASONABLY ESTIMATED) AND ASSOCIATED REPAIR COSTS

Defect Location	Location / Type of Defect	I&I POTENTIAL	Recommended Repair	Est. Cost	Running Total \$
COOK ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$500
E. 12TH ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$1,000
7TH AVE.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$1,500
E. LIBERTY ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$2,000
S. SEMINARY ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$2,500
S. CHURCH ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$3,000
S. CHURCH ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$3,500
S. SEMINARY ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$4,000
BLAKELEY PL.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$4,500
MARTIN ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$5,000
EUCLID AVE.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$5,500
S. SAMUEL ST.	SUMP PUMP CONNECTED TO SEWER	HIGH	DISCONNECT SUMP PUMP	\$500	\$6,000

NOTES:

1. Public I&I sources (within the right-of-way) are not presented in this table.
2. The estimated costs are supplied for guidance only, and represent only construction costs. Administrative and Engineering costs are not included in these figures. The accuracy of the cost estimates may fluctuate due to labor and material prices, competitive bidding and market conditions.